



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Raquel M. Filmanowicz
Health Operations Administrator

Health Department

Family and Community Health Services

web site: www.milwaukee.gov/health

Routine Food Reinspection #2

ROBERT PYLES
BETTY PYLES
MCDONALD'S
8100 W BROWN DEER RD
MILWAUKEE, WI

6/13/2011

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Fee Amount:
\$173.00

| Code Number | Description of Violation | Correct By |
|-------------|---|------------|
| 5-202.11 | <ol style="list-style-type: none">1. There is condensate buildup on the floor and food packages in the basement walk in freezer. Remove buildup and properly repair freezer to code using approved materials.2. There is what appears to be grease leaking from pipes in the basement ceiling. Find source of grease accumulation and properly repair to code using approved materials.3. There is leak in the rinse compartment of the 4 compartment sink. Properly repair to code using approved materials.4. There is a leak beneath the dish machine. Properly repair to code using approved materials.5. There is a pipe leaking in the basement to the left of the washing machine. Properly repair to code using approved materials. | 3/7/2011 |

Notes:

On 6/13/2011, I served these orders upon ROBERT PYLES
BETTY PYLES by leaving this report with



Tom Barrett
Mayor

Bevan K. Baker, FACHE
Commissioner of Health

Raquel M. Filmanowicz
Health Operations Administrator

Health Department

Family and Community Health Services

web site: www.milwaukee.gov/health

Open Items:

Grease leak in the basement ceiling. This must be repaired by 06-20-11 or provide a written work order with a completion date.



Operator Signature

